

# FUNCTIONAL SAFETY CERTIFICATE

CERTIFICATO – ZERTIFIKAT – CERTIFICADO – CERTIFICAT

The product:

*High Temperature Velocity Transducer  
5485C*

Manufactured by:

*Metrix Instruments Co.  
8824 Fallbrook Dr. Houston, TX 77064  
United States of America*

suitable for the following safety function(s):

Generate an emf directly proportional to the oscillatory velocity applied to the sensor body by the external environment

has been assessed per the relevant requirements of

**IEC 61508:2010 Parts 1 to 7**

and meets the requirements providing the following:

## Systematic Capability:

The compliance with the requirements for the avoidance of systematic faults and the requirements for the control of systematic faults have been achieved following the compliance route 1<sub>S</sub>.

SC 3

## Hardware Safety Integrity:

The constraints on hardware safety integrity have been verified in order to achieve a sufficiently robust architecture taking into account the level of element and subsystem complexity following the compliance route 1<sub>H</sub>.

Type  
A

## Random Safety Integrity:

The estimated safety integrity, for each safety function, due to random hardware safe and dangerous failures rates (excluding "no part" and "no effect" contribution).

See  
page  
2

The architectural constraints and the effects of random failures (PFH/PFD<sub>AVG</sub>) must be verified for each specific application and safety function implemented by the E/E/PE safety-related system.

Certified by:

**BYHON**

BYHON Certification Director:

  
Rosati Francesco

CERTIFICATE No:  
MTXI-5485C-ENS-E01  
Revision: A

Issued:  
February 28<sup>th</sup>, 2022

Valid until:  
March 1<sup>st</sup>, 2025

The owner of a valid certificate for an assessed product is authorized to affix the following mark and relative ID number, to all recognized devices which are identical to the product assessed.

**BYHON**  
**SIL** ✓

**ID.N°010522EN04A**



#8914  
ISO/IEC 17065  
Product Certification Body

The design of each Safety Instrumented Function (SIF) shall meet the requirements listed in the reference standards that shall be selected by taking into account the specific application. Specific activities necessary to investigate and reach a judgment on the adequacy of the functional safety achieved by the E/E/PE safety-related system or compliant items (elements/subsystems) has been conducted by an independent assessor.

The following failure rates data shall be used to the PFH/PFD<sub>AVG</sub> estimation, taking into consideration all parameters such as redundancy, architectural constraints, diagnostic capability, also introduced by the whole system, including the considerations about the proof test and its effectiveness, mean time of restoration, up to the maintenance capability and its minimum characteristics.

**Failure rate for Seismic Transmitters 5485C**

Configuration	$\lambda_s$	$\lambda_{DU}$	$\lambda_{DD}$
With Removal Cable (5485-AAA + 4850-AAA)	0	77	392
With integral Cable (5485-AAA-BBB)	0	78	311

Notes:

- All failure rates are in FIT (Failure In Time 1 FIT = 1 failure / 10<sup>9</sup> hours).
- The device, in both configurations, can be used for application up to SIL 2, with HFT=0, and SIL 3, with HFT=1.

The prescriptions contained in the safety manual QP064-46 shall be followed.

CERTIFICATE NO:  
**MTXI-5485C-ENS-E01**

Revision: A

Issued:  
February 28<sup>th</sup>, 2022

Valid until:  
**March 01<sup>st</sup>, 2025**

The Functional Safety  
Assessment report no.

**22-MTX-5485C-FSA-01**

dated:  
February 23<sup>rd</sup>, 2022

is an integral part of this  
certificate



Mod\_12\_CB Rev03

BYHON  
Via Lepanto 23, 59100  
Prato (PO)  
ITALY



**The following pages are the prior revisions of this certificate.**



# CERTIFICATE

CERTIFICATO – ZERTIFICAT – CERTIFICADO – CERTIFICAT

The product:

*High Temperature Velocity Transducer  
5485C*

Manufactured by:

*Metrix Instrument Co.  
8824 Fallbrook Drive, Houston  
Texas 77064  
United States*

Is suitable for the following safety function(s):

Generate an emf directly proportional to the oscillatory velocity applied to the sensor body by the external environment, suitable to vibration monitoring of rotating machinery.

Has been assessed per the relevant requirements of:

**IEC 61508:2010 Parts 1 to 7**

and meets the requirements providing the following:

## Systematic Capability:

The compliance with the requirements for the avoidance of systematic faults and the requirements for the control of systematic faults have been achieved following the compliance route 1<sub>s</sub>.

**SC 3**

## Hardware Safety Integrity:

The constraints on hardware safety integrity have been verified in order to achieve a sufficiently robust architecture taking into account the level of element and subsystem complexity following the compliance route 1<sub>H</sub>.

**Type  
A**

## Random Safety Integrity:

The estimated safety integrity, for each safety function, due to random hardware failures (including soft-errors) and random failures of data communication processes.

**See  
page  
2**

The architectural constraints and the effects of random failures (PFD<sub>AVG</sub>) must be verified for each specific application and safety function implemented by the E/E/PE safety-related system.

Certified by:

**HON**  
CONSULTING

Legal Representative:

  
Rosati Francesco

President of HON Consulting S.r.l.



CERTIFICATE NO:  
MIC-5485-E01-ESLC-S01  
Revision: A

Issued:  
February 28th, 2017

Valid until:  
February 27th, 2022

The owner of a valid certificate for an assessed product is authorized to affix the following mark to all recognized devices which are identical to the product assessed.



With the following  
ID number:

**17-105S01A**

METRIX DOC NO: 1699560  
REV: A



The design of each Safety Instrumented Function shall meet the requirements listed in the reference standards that shall be selected by taking into account the specific application.

Specific activities necessary to investigate and reach a judgment on the adequacy of the functional safety achieved by the E/E/PE safety-related system or compliant items (elements/subsystems) has been conducted by an independent assessor.

The following failure rates data shall be used to the PFD<sub>AVG</sub> estimation, taking into consideration all parameters such as redundancy, architectural constraints, diagnostic capability, also introduced by the whole system, including the considerations about the proof test and its effectiveness, mean time of restoration, up to the maintenance capability and its minimum characteristics.

Failure rate of 5485C High Temperature Velocity Transducer

with removable cable (5485C-AAA + 4850-AAA)				with integral cable (5485C-AAA-BBB)			
$\lambda_{SU}$	$\lambda_{SD}$	$\lambda_{DU}$	$\lambda_{DD}$	$\lambda_{SU}$	$\lambda_{SD}$	$\lambda_{DU}$	$\lambda_{DD}$
0	0	98	716	0	0	104	712

Note:

- All failure rates are in FIT (Failure In Time 1 FIT = 1 failure / 10<sup>9</sup> hours).

The prescriptions contained in the safety manual, available on the Metrix website, shall be followed.



CERTIFICATE NO:  
MIC-5485-E01-ESLC-S01  
Revision: A

Issued:  
February 28th, 2017

Valid until:  
February 27th, 2022

The Functional Safety  
Assessment report no.

C306-105-021600\_ESLC-S01\_01

dated:  
February 27st, 2017

is an integral part of this  
certificate

