

# FUNCTIONAL SAFETY CERTIFICATE

CERTIFICATO – ZERTIFIKAT – CERTIFICADO – CERTIFICAT

The product:

*Industrial Seismic Accelerometer SA6200A*

Manufactured by:

*Metrix Instruments Co.  
8824 Fallbrook Dr. Houston, TX 77064  
United States of America*

suitable for the following safety function(s):

To monitor constantly the machine vibration level at the portion where the device is installed and to provide an analog voltage output proportional to the measured vibration (mV/g)

has been assessed per the relevant requirements of

**IEC 61508:2010 Parts 1 to 7**

and meets the requirements providing the following:

## Systematic Capability:

The compliance with the requirements for the avoidance of systematic faults and the requirements for the control of systematic faults have been achieved following the compliance route 1<sub>S</sub>.

SC 3

## Hardware Safety Integrity:

The constraints on hardware safety integrity have been verified in order to achieve a sufficiently robust architecture taking into account the level of element and subsystem complexity following the compliance route 1<sub>H</sub>.

Type  
A

## Random Safety Integrity:

The estimated safety integrity, for each safety function, due to random hardware safe and dangerous failures rates (excluding "no part" and "no effect" contribution).

See  
page  
2

The architectural constraints and the effects of random failures (PFH/PFD<sub>AVG</sub>) must be verified for each specific application and safety function implemented by the E/E/PE safety-related system.

Certified by:

**BYHON**

BYHON Certification Director:

  
Rosati Francesco

CERTIFICATE No:  
MTXI-6200A-ENS-E01  
Revision: A

Issued:  
June 15<sup>th</sup>, 2022

Valid until:  
June 14<sup>th</sup>, 2025

The owner of a valid certificate for an assessed product is authorized to affix the following mark and relative ID number, to all recognized devices which are identical to the product assessed.

**BYHON**  
**SIL** ✓

**ID.N° 010522EN06A**



#8914  
ISO/IEC 17065  
Product Certification Body

The design of each Safety Instrumented Function (SIF) shall meet the requirements listed in the reference standards that shall be selected by taking into account the specific application. Specific activities necessary to investigate and reach a judgment on the adequacy of the functional safety achieved by the E/E/PE safety-related system or compliant items (elements/subsystems) has been conducted by an independent assessor.

The following failure rates data shall be used to the PFH/PFD<sub>AVG</sub> estimation, taking into consideration all parameters such as redundancy, architectural constraints, diagnostic capability, also introduced by the whole system, including the considerations about the proof test and its effectiveness, mean time of restoration, up to the maintenance capability and its minimum characteristics.

**Device failure rates**

Configuration	$\lambda_s$	$\lambda_{DU}$	$\lambda_{DD}$
With external out-of-range diagnostics	-	64	102
Without external diagnostics	-	166	-

Note:

- All failure rates are in FIT (Failure In Time 1 FIT = 1 failure / 10<sup>9</sup> hours).

The prescriptions contained in the safety manual no. QP064-45 shall be followed.

CERTIFICATE NO:  
**MTXI-6200A-ENS-E01**

Revision: A

Issued:  
June 15<sup>th</sup>, 2022

Valid until:  
June 14<sup>th</sup>, 2025

The Functional Safety  
Assessment report no.

**22-MTX-6200A-FSA-01**

dated:  
June 14<sup>th</sup>, 2022

is an integral part of this  
certificate



Mod\_12\_CB Rev03

BYHON  
Via Lepanto 23, 59100  
Prato (PO)  
ITALY