



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.:	<b>IECEX BAS 15.0095X</b>	Page 1 of 4	<u>Certificate history:</u> Issue 0 (2015-09-07)
Status:	<b>Current</b>	Issue No: 1	
Date of Issue:	2024-03-22		
Applicant:	<b>Metrix Instrument Co.</b> 8824 Fallbrook Houston Texas 77064 <b>United States of America</b>		
Equipment:	<b>Model 5485C Velocity Transducer</b>		
Optional accessory:			
Type of Protection:	<b>Type ec</b>		
Marking:	<b>Ex ec IIC T* Gc</b> <b>Temperature Class - see Specific Conditions of Use</b>		

Approved for issue on behalf of the IECEx  
Certification Body:

**P Oates**

Position:

**Certification Manager**

Signature:  
(for printed version)

Date:  
(for printed version)

22/3/2024

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting [www.iecex.com](http://www.iecex.com) or use of this QR Code.



Certificate issued by:

**SGS UK Limited**  
**Rockhead Business Park**  
**Staden Lane**  
**Buxton, Derbyshire SK17 9RZ**  
**United Kingdom**

METRIX Doc No: 1480831  
REV: B



# IECEX Certificate of Conformity

Certificate No.: **IECEX BAS 15.0095X**

Page 2 of 4

Date of issue: 2024-03-22

Issue No: 1

Manufacturer: **Metrix Instrument Co.**  
8824 Fallbrook  
Houston  
Texas 77064  
**United States of America**

Manufacturing locations: **Metrix Instrument Co.**  
8824 Fallbrook  
Houston  
Texas 77064  
**United States of America**

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

#### STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements  
Edition:7.0

[IEC 60079-7:2017](#) Explosive atmospheres - Part 7: Equipment protection by increased safety "e"  
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

#### TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[GB/BAS/ExTR15.0245/00](#)

[GB/SGS/ExTR24.0049/00](#)

Quality Assessment Report:

[GB/BAS/QAR10.0017/09](#)

METRIX Doc No: 1480831  
REV: B



# IECEX Certificate of Conformity

Certificate No.: **IECEX BAS 15.0095X**

Page 3 of 4

Date of issue: 2024-03-22

Issue No: 1

## EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The Model 5485C Velocity Transducer is designed to measure vibrations and convert them into an output signal. It comprises a coil and magnet housed within a stainless steel enclosure. Electrical connections are made via a two-pole connector or integral cable.

## Input parameters

Max rated input: 28V

## SPECIFIC CONDITIONS OF USE: YES as shown below:

1. The Temperature Classification and ambient temperature range of the Model 5485C can vary and may be as follows:

T6	$-54^{\circ}\text{C} \leq T_a \leq +45^{\circ}\text{C}$
T5	$-54^{\circ}\text{C} \leq T_a \leq +60^{\circ}\text{C}$
T4	$-54^{\circ}\text{C} \leq T_a \leq +95^{\circ}\text{C}$
T3	$-54^{\circ}\text{C} \leq T_a \leq +160^{\circ}\text{C}$
T2	$-54^{\circ}\text{C} \leq T_a \leq +260^{\circ}\text{C}$
T1	$-54^{\circ}\text{C} \leq T_a \leq +375^{\circ}\text{C}$

2. The terminations of the flying leads of the integral cable must be afforded a degree of protection of at least IP54 in accordance with the requirements of IEC 60079-15 and EN/IEC 60529.

3. External provision must be made to ensure that the maximum rated input is not exceeded by more than 40%.

4. The connector must not be disconnected whilst the equipment is energised.



# IECEX Certificate of Conformity

Certificate No.: **IECEX BAS 15.0095X**

Page 4 of 4

Date of issue: 2024-03-22

Issue No: 1

## **DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)** **Variation 1.1**

This issue of the certificate permits minor drawing changes and confirms that the current design meets the requirements of IEC 60079-0:2017 Ed 7 & IEC 60079-7:2017 Ed 5.1 for Ex ec equipment, including the revision of the equipment marking in accordance with these standards.

ExTR: **GB/SGS/ExTR24.0049/00**

File Reference: **20/0577**



**The following pages are the prior revisions of this certificate.**



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx BAS 15 0095X issue No.:0 Certificate history:

Status: Current

Date of Issue: 2015-09-07 Page 1 of 3

Applicant: **Metrix Instrument Co.**  
8824 Fallbrook  
Houston  
Texas 77064  
United States of America

Electrical Apparatus: **Model 5485C Velocity Transducer**  
Optional accessory:

Type of Protection: **Type n**

Marking: **Ex nA IIC T\* Gc**  
Temperature Class - see schedule

Approved for issue on behalf of the IECEx Certification Body:

R. S. Sinclair *PP DIBREANLEY*

Position: Technical Manager

Signature:  
(for printed version)

*RS Sinclair*  
\_\_\_\_\_  
10/9/15

- Date:
1. This certificate and schedule may only be reproduced in full.
  2. This certificate is not transferable and remains the property of the issuing body.
  3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

**SGS Baseefa Limited**  
Rockhead Business Park  
Staden Lane  
Buxton  
Derbyshire  
SK17 9RZ  
United Kingdom





# IECEX Certificate of Conformity

Certificate No.: IECEx BAS 15.0095X

Date of Issue: 2015-09-07

Issue No.: 0

Page 2 of 3

Manufacturer: **Metrix Instrument Co.**  
8824 Fallbrook  
Houston  
Texas 77064  
**United States of America**

Additional Manufacturing location  
(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

**IEC 60079-0 : 2011** Explosive atmospheres - Part 0: General requirements  
Edition: 6.0

**IEC 60079-15 : 2010** Explosive atmospheres - Part 15: Equipment protection by type of protection "n"  
Edition: 4

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

##### Test Report:

[GB/BAS/ExTR15.0245/00](#)

##### Quality Assessment Report:

[GB/BAS/QAR10.0017/03](#)



# IECEx Certificate of Conformity

Certificate No.: IECEx BAS 15.0095X

Date of Issue: 2015-09-07

Issue No.: 0

Page 3 of 3

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

The Model 5485C Velocity Transducer is designed to measure vibrations and convert them into an output signal. It comprises a coil and magnet housed within a stainless steel enclosure. Electrical connections are made via a two-pole connector or integral cable.

### Input parameters

Max rated input: 28V

### CONDITIONS OF CERTIFICATION: YES as shown below:

1. The Temperature Classification and ambient temperature range of the Model 5485C can vary and may be as follows:

T6	$-54^{\circ}\text{C} \leq T_a \leq +45^{\circ}\text{C}$
T5	$-54^{\circ}\text{C} \leq T_a \leq +60^{\circ}\text{C}$
T4	$-54^{\circ}\text{C} \leq T_a \leq +95^{\circ}\text{C}$
T3	$-54^{\circ}\text{C} \leq T_a \leq +160^{\circ}\text{C}$
T2	$-54^{\circ}\text{C} \leq T_a \leq +260^{\circ}\text{C}$
T1	$-54^{\circ}\text{C} \leq T_a \leq +375^{\circ}\text{C}$

2. The terminations of the flying leads of the integral cable must be afforded a degree of protection of at least IP54 in accordance with the requirements of IEC 60079-15 and EN/IEC 60529.

3. External provision must be made to ensure that the maximum rated input is not exceeded by more than 40%.

4. The connector must not be disconnected whilst the equipment is energised.