



# 中国国家强制性产品认证证书



证书编号: 2020322304003134

认证委托人名称: 儒博控制系统制造(上海)有限公司  
 认证委托人地址: 上海市嘉定区马陆镇龙盘路568号7幢  
 生产者名称: 迈确仪表公司  
 生产者地址: 8824 Fallbrook Dr. Houston, TX 77064 United States  
 生产企业名称: 迈确仪表公司  
 生产企业地址: 8824 Fallbrook Dr. Houston, TX 77064 United States  
 产品名称: 机械震动开关  
 系列、规格、型号: 5550G  
 标准: GB 3836.1-2010、GB 3836.2-2010

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求, 特发此证。

发证日期: 2020年11月4日      有效期至: 2025年11月3日

首次发证日期: 2020年11月4日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



批准:



## 上海仪器仪表自控系统检验测试所有限公司

<http://www.sitiias.com.cn>

中国·上海·漕宝路103号200233

电话: +86 21 64510844

S 0003246

METRIX DOC NO: 1904416  
REV: A



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



**CERTIFICATE NO: 2020322304003134**

**APPLICANT:** Roper Industries Manufacturing (Shanghai) Co.,Ltd.  
**ADDRESS:** Bd.7A,No.568,Longpan Rd.Malu Jiading Shanghai  
**MANUFACTURER:** Metrix Instrument Co., LP  
**ADDRESS:** 8824 Fallbrook Dr. Houston, TX 77064 United States  
**FACTORY:** Metrix Instrument Co., LP  
**ADDRESS:** 8824 Fallbrook Dr. Houston, TX 77064 United States  
**PRODUCTNAME:** Mechanical vibration switch  
**SERIES,SPECIFICATION,MODEL:** 5550G  
**STANDARDS:** GB 3836.1-2010、GB 3836.2-2010

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

**Valid from:**November 4, 2020

**Valid until:** November 3, 2025

**Date of original certification:**November 4, 2020

**The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.**

This certificate is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



APPROVAL:

Xu JianPing



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**

<http://www.sitiias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

METRIX DOC NO: 1904416  
REV: A

S 0002105



# 中国国家强制性产品认证证书



**SITIAs**  
Worldwide Access

证书编号: 2020322304003134

## 附件

产品名称: 机械震动开关

型号规格: 5550G  
5550-ABC-DEF, A代表危险区域等级, 可为G; B代表继电器触点, 可为1、2、3、4; C代表复位/起机延时线圈保持强度, 可为1、2、3; D代表复位/起机延时线圈电压, 可为1、2、3、4; E代表接线入口/安装板孔模式, 可为9; F代表环境等级, 可为2.

防爆标志: Ex d IIC T6 Gb

电气参数: 微动开关额定电压480V AC 15A, 线圈额定电压230V AC 1A或 24V DC 3A.

批 准:



### 上海仪器仪表自控系统检验测试所有限公司