

# FUNCTIONAL SAFETY CERTIFICATE

CERTIFICATO – ZERTIFIKAT – CERTIFICADO – CERTIFICAT

The product:

*Seismic Velocity Transmitter ST5484E*  
*Vibration Transmitter ST5491E (All configurations)*

Manufactured by:

*Metrix Instruments Co.*  
*18824 Fallbrook Dr. Houston, TX 77064*  
*United States of America*

suitable for the following safety function(s):

To provide a 4-20mA DC signal output proportional to the vibration amplitude of rotating equipment portion where installed

has been assessed per the relevant requirements of

**IEC 61508:2010 Parts 1 to 2**

and meets the requirements providing the following:

## Systematic Capability:

The compliance with the requirements for the avoidance of systematic faults and the requirements for the control of systematic faults have been achieved following the compliance Route 1s.

SC 2

## Hardware Safety Integrity:

The constraints on hardware safety integrity have been verified in order to achieve a sufficiently robust architecture taking into account the level of element and subsystem complexity following the compliance Routes 1<sub>H</sub> and 2<sub>H</sub>.

Type  
A

## Random Safety Integrity:

The estimated safety integrity, for each safety function, due to random hardware safe and dangerous failures rates (excluding "no part" and "no effect" contribution).

See  
page  
2

The architectural constraints and the effects of random failures (PFH/PFD<sub>AVG</sub>) must be verified for each specific application and safety function implemented by the E/E/PE safety-related system.

Certified by:

**BYHON**

BYHON Certification Director:

*Rosati Francesco*

Rosati Francesco

CERTIFICATE No:

MTXI-5484E-ENS-B01

Issued:

May 23<sup>rd</sup>, 2025

Valid until:

May 22<sup>nd</sup>, 2028

The owner of a valid certificate for an assessed product is authorized to affix the following mark to all recognized devices which are identical to the product assessed.

**BYHON**  
**SIL** ✓



ANSI National Accreditation Board

ACCREDITED

ISO/IEC 17065

PRODUCT CERTIFICATION  
BODY

#8914

\*The Certificate shall be reproduced only in its original entirety

The design of each Safety Instrumented Function (SIF) shall meet the requirements listed in the reference standards that shall be selected by taking into account the specific application. Specific activities necessary to investigate and reach a judgment on the adequacy of the functional safety achieved by the E/E/PE safety-related system or compliant items (elements/subsystems) has been conducted by an independent assessor.

The following failure rates data shall be used to the PFH/PFD<sub>AVG</sub> estimation, taking into consideration all parameters such as redundancy, architectural constraints, diagnostic capability, also introduced by the whole system, including the considerations about the proof test and its effectiveness, mean time of restoration, up to the maintenance capability and its minimum characteristics.

Failure rate for ST5484E and ST5491E - All configurations

Product	Series	$\lambda_s$	$\lambda_{DU}$	$\lambda_{DD}$
Seismic Velocity Transmitter	ST5484E	94	117	114
Vibration Transmitter	ST5491E			

Note:

- All failure rates are in FIT (Failure In Time 1 FIT = 1 failure / 10<sup>9</sup> hours).
- The prescriptions contained in the safety manual QP064-42 shall be followed.
- The device can be used in SIL 2 application with HFT=0. In any case, the SIL reached by the entire Safety Instrumented Function (SIF) must be verified by the System Integrator / Final User considering demand mode, architectures, proof test interval and effectiveness, availability of diagnostics.

CERTIFICATE NO:  
MTXI-5484E-ENS-B01

Issued:  
May 23<sup>rd</sup>, 2025

Valid until:  
May 22<sup>nd</sup>, 2028

The Functional Safety  
Assessment report no.

25-MTX-5484E-FSA-01

dated:  
May 23<sup>rd</sup>, 2025

is an integral part of this  
certificate



Mod\_12\_CB Rev09

BYHON  
Via Lepanto 23, 59100  
Prato (PO)  
ITALY

\*The Certificate shall be reproduced only in its  
original entirety.



**The following pages are the prior revisions of this certificate.**



# FUNCTIONAL SAFETY CERTIFICATE

CERTIFICATO – ZERTIFIKAT – CERTIFICADO – CERTIFICAT

The product:

***Seismic Transmitters ST5484E and ST5491E  
(all configurations)***

Manufactured by:

***Metrix Instruments Co.  
8824 Fallbrook Dr. Houston, TX 77064  
United States of America***

suitable for the following safety function(s):

- . Provides a 4-20mA DC signal output proportional to the vibration amplitude of rotating equipment portion where installed.

has been assessed per the relevant requirements of

**IEC 61508:2010 Parts 1 to 7**

and meets the requirements providing the following:

## Systematic Capability:

The compliance with the requirements for the avoidance of systematic faults and the requirements for the control of systematic faults have been achieved following the compliance route 1<sub>S</sub>.

**SC 2**

## Hardware Safety Integrity:

The constraints on hardware safety integrity have been verified in order to achieve a sufficiently robust architecture taking into account the level of element and subsystem complexity following the compliance route 1<sub>H</sub>.

**Type  
A**

## Random Safety Integrity:

The estimated safety integrity, for each safety function, due to random hardware safe and dangerous failures rates (excluding "no part" and "no effect" contribution).

**See  
page  
2**

The architectural constraints and the effects of random failures (PFH/PFD<sub>AVG</sub>) must be verified for each specific application and safety function implemented by the E/E/PE safety-related system.

Certified by:

**BYHON**

BYHON Certification Director:

  
Rosati Francesco

CERTIFICATE No:

**MTXI-5484E-ENS-E01**

Revision: A

Issued:

February 16<sup>th</sup>, 2022

Valid until:

February 15th, 2025

The owner of a valid certificate for an assessed product is authorized to affix the following mark and relative ID number, to all recognized devices which are identical to the product assessed.

**BYHON**  
**SIL** ✓

**ID.N° 010522E03N**



#8914  
ISO/IEC 17065  
Product Certification Body

The design of each Safety Instrumented Function (SIF) shall meet the requirements listed in the reference standards that shall be selected by taking into account the specific application. Specific activities necessary to investigate and reach a judgment on the adequacy of the functional safety achieved by the E/E/PE safety-related system or compliant items (elements/subsystems) has been conducted by an independent assessor.

The following failure rates data shall be used to the PFH/PFD<sub>AVG</sub> estimation, taking into consideration all parameters such as redundancy, architectural constraints, diagnostic capability, also introduced by the whole system, including the considerations about the proof test and its effectiveness, mean time of restoration, up to the maintenance capability and its minimum characteristics.

Failure rate for Seismic Transmitters ST5484E and ST5491E– All configurations

$\lambda_{SU}$	$\lambda_{SD}$	$\lambda_{DU}$	$\lambda_{DD}$	$\lambda_{RES}$
94	0	117	114	640

Note:

- The  $\lambda_{RES}$  (RESIDUAL) failure rates includes the NO PART and NO EFFECT failure rates.
- All failure rates are in FIT (Failure In Time 1 FIT = 1 failure / 10<sup>9</sup> hours).

The prescriptions contained in the safety manual QP064-42 shall be followed.

CERTIFICATE NO:  
**MTXI-5484E-ENS-E01**  
Revision: A

Issued:  
February 16<sup>th</sup>, 2022

Valid until:  
February 15<sup>th</sup>, 2025

The Functional Safety  
Assessment report no.

**22-MTX-5484E-FSA-01**

dated:  
February 16<sup>th</sup>, 2022

is an integral part of this  
certificate



Mod\_12\_CB Rev03

BYHON  
Via Lepanto 23, 59100  
Prato (PO)  
ITALY



**The following pages are the prior revisions of this certificate.**



# CERTIFICATE

CERTIFICATO – ZERTIFIKAT – CERTIFICADO – CERTIFICAT

The product:

**Seismic Transmitters STS484E and STS491E  
(all configurations)**

Manufactured by:

**Metrix Instruments Co.**  
8824 Fallbrook Dr. Houston, TX 77064  
United States of America

suitable for the following safety function(s):

Provides a 4-20mA DC signal output proportional to the vibration amplitude of rotating equipment portion where installed.

has been assessed per the relevant requirements of

**IEC 61508:2010 Parts 1 to 7**

and meets the requirements providing the following:

## Systematic Capability:

The compliance with the requirements for the avoidance of systematic faults and the requirements for the control of systematic faults have been achieved following the compliance route 1:

SC 2

## Hardware Safety Integrity:

The constraints on hardware safety integrity have been verified in order to achieve a sufficiently robust architecture taking into account the level of element and subsystem complexity following the compliance route 1:

Type  
A

## Random Safety Integrity:

The estimated safety integrity, for each safety function, due to random hardware safe and dangerous failures rates (excluding "no part" and "no effect" contribution),

See  
page  
2

The architectural constraints and the effects of random failures (PFH/PPFD<sub>avg</sub>) must be verified for each specific application and safety function implemented by the E/E/PE safety-related system.

Certified by:

**BYHON**

BYHON Certification Director:



Rosati Francesco

CERTIFICATE No:

**MTXI-5484E-ENS-E01**

Revision: A

Issued:

July 31st, 2019

Valid until:

July 30th, 2022

The owner of a valid certificate for an assessed product is authorized to affix the following mark and relative ID number, to all recognized devices which are identical to the product assessed.

**BYHON**  
**SIL** ✓

ID.N° 500719E01N



The design of each Safety Instrumented Function (SIF) shall meet the requirements listed in the reference standards that shall be selected by taking into account the specific application. Specific activities necessary to investigate and reach a judgment on the adequacy of the functional safety achieved by the E/E/PE safety-related system or compliant items (elements/subsystems) has been conducted by an independent assessor.

The following failure rates data shall be used to the PFH/PFD<sub>RMS</sub> estimation, taking into consideration all parameters such as redundancy, architectural constraints, diagnostic capability, also introduced by the whole system, including the considerations about the proof test and its effectiveness, mean time of restoration, up to the maintenance capability and its minimum characteristics.

Failure rate for Seismic Transmitters STS484E and STS491E– All configurations

$\lambda_{SU}$	$\lambda_{SD}$	$\lambda_{OU}$	$\lambda_{OD}$	$\lambda_{RES}$
94	0	117	114	640

- Note:
- All failure rates are in FIT (Failure In Time 1 FIT = 1 failure / 10<sup>9</sup> hours).
  - The  $\lambda_{RES}$  (RESIDUAL) failure rates includes the NO PART and NO EFFECT failure rates.

The prescriptions contained in the safety manual QP064-42 shall be followed.

CERTIFICATE NO:  
MTXI-5484E-ENS-E01

Revision: A

Issued:  
July 31st, 2019

Valid until:  
July 30th, 2022

The Functional Safety  
Assessment report no.

19-MTX-5484E-FSA-01

dated:  
July 29th, 2019

is an integral part of this  
certificate

