






EU Declaration of Conformity

TXA/TXR/TXR5521 Proximity Probe Transmitter

Manufacturer's Name	Metrix Instrument Co., L.P.
Manufacturer's Address	8824 Fallbrook Drive, Houston, TX 77064 USA 281.940.1802 www.metrixvibration.com info@metrixvibration.com
Declares that the product	Models TXA/TXR/TXR5521 Proximity Probe Transmitter (This declaration of conformity is issued under the sole responsibility of Metrix Instrument)
Directive 2014/34/EU ATEX	Provision of the Directive fulfilled by the Equipment <ul style="list-style-type: none">•  II 1 G, Ex ia IIC T4 Ga (Ta -40°C to +85°C)•  II 3 G, Ex nA IIC T4 Gc (Ta -40°C to +85°C)
Conforms to the following standards	ATEX <ul style="list-style-type: none">• EN 60079-0:2012• EN 60079-11:2012• EN 60079-15:2010
EU-Type Examination	Certificate <ul style="list-style-type: none">• Baseefa05ATEX0195X• Baseefa06ATEX0113X• SGS Baseefa Limited Rockhead Business Park, Staden Lane Buxton, Derbyshire SK17 9RZ UNITED KINGDOM Notified Body Number: 1180
Notified Body for production	SGS Fimko Oy (Notified Body Number: 0598) Helsinki, Finland
Directive 2014/30/EU	EMC <ul style="list-style-type: none">• EN 61326-1: 2013 (self-certified)• EN 61326-1: 2006• Professional Testing (EMI), Inc. 1601 North A.W. Grimes Blvd., Suite B Round Rock, Texas 78665 NVLAP: Lab Code 200062-0
Technical File Location	The Technical File required by this Directive is maintained by the manufacturer listed above and the address listed above.
Approved By	 Lance Truong Quality Manager, Metrix Instrument Co. Houston, Texas October 23, 2020