







## EU/UK Declaration of Conformity

### ST5484E Velocity Transmitter and SW5484E Vibration Switch

<b>Manufacturer's Name</b>	Metrix Instrument Co., L.P.
<b>Manufacturer's Address</b>	8824 Fallbrook Drive, Houston, TX 77064 USA 281.940.1802 www.metrixvibration.com <a href="mailto:info@metrixvibration.com">info@metrixvibration.com</a>
<b>Declares that the product</b>	Model ST5484E Velocity Transmitter and SW5484E Vibration Switch (This declaration of conformity is issued under the sole responsibility of Metrix Instrument)
<b>Directive 2014/34/EU ATEX SI 2016 no. 1107 UKEX</b>	<b>Provision of the Directive fulfilled by the Equipment</b> <ul style="list-style-type: none"><li>•  II 1 G, Ex ia IIC T4 Ga (Ta -40°C to +100°C)</li><li>•  II 2 G, Ex db IIC T* Gb</li><li>•  II 3 G, Ex ec IIC T* Gc</li><li>• T* - T4: Ta -40°C to +100°C, T6: Ta -40°C to +73°C)</li></ul>
<b>Conforms to the following harmonized/designated standards</b>	<b>ATEX/UKEX</b> <ul style="list-style-type: none"><li>• EN IEC 60079-0:2018</li><li>• EN 60079-1:2014</li><li>• EN IEC 60079-7:2015+A1:2018</li><li>• EN 60079-11:2012</li></ul>
<b>EU/UK-Type Examination</b>	<b>Certificate</b> <ul style="list-style-type: none"><li>• CML 23ATEX1249X/CML 23UKEX1250X (Ex ia &amp; Ex d)</li><li>• CML 23ATEX3328X/CML 23UKEX3329X (Ex ec)</li><li>• CML B.V. Koopvaardijweg 32, 4906CV Oosterhout, The Netherlands Notified Body Number: 2776</li></ul>
<b>Notified/Approved Body for production</b>	ATEX - SGS Fimko Oy (Notified Body Number 0598) Helsinki, Finland UKEX - SGS Bseefa Ltd. (Approved Body Number 1180) Buxton, United Kingdom
<b>Directive 2014/30/EU</b>	<b>EMC</b> <ul style="list-style-type: none"><li>• EN 61326-1: 2013 (self-certified)</li><li>• EN 61326-1: 2006</li><li>• Professional Testing (EMI), Inc. 1601 North A.W. Grimes Blvd., Suite B Round Rock, Texas 78665 NVLAP: Lab Code 200062-0</li></ul>
<b>Technical File Location</b>	The Technical File required by this Directive is maintained by the manufacturer listed above and the address listed above.
<b>Approved By</b>	  Lance Truong Quality Manager, Metrix Instrument Co. Houston, Texas July 29, 2025